

School Name	Location	Copper (Cu) ug/L	Lead (Pb) ug/L	Result	Remediation
Aspotogan Consolidated Elementary	S Room 120 boiler room	9.4	8.6	Exceeds Limit	Signage to be added to instruct handwashing only
Aspotogan Consolidated Elementary	S Room 168 Music room	27.0	1.9	Passed	
Aspotogan Consolidated Elementary	S Room 171 washroom	16.0	-	Passed	
Aspotogan Consolidated Elementary	S Room 123 classroom	130.0	2.4	Passed	
Aspotogan Consolidated Elementary	S Room 124 classroom	20.0	1.2	Passed	
Aspotogan Consolidated Elementary	S 126 in hall water fountain	4.6	-	Passed	
Aspotogan Consolidated Elementary	S 129 sink in main room	20.0	8.0	Exceeds Limit	Signage to be added to instruct handwashing only
Aspotogan Consolidated Elementary	S 129 sink in kitchenette	10.0	3.9	Passed	
Aspotogan Consolidated Elementary	S 129 sink in washroom	12.0	0.8	Passed	
Aspotogan Consolidated Elementary	S 133 washroom (135)	14.0	-	Passed	
Aspotogan Consolidated Elementary	S 133 washroom (134)	76.0	1.6	Passed	
Aspotogan Consolidated Elementary	S 133 sink in main room	32.0	-	Passed	
Aspotogan Consolidated Elementary	S 162 girls change room bathroom sink	28.0	2.7	Passed	
Aspotogan Consolidated Elementary	S 161 Gym office	290.0	36.0	Exceeds Limit	Signage to be added to instruct handwashing only
Aspotogan Consolidated Elementary	S 157 boys change room bathroom sink	380.0	3.5	Passed	
Aspotogan Consolidated Elementary	S 137 classroom sink	16.0	4.4	Passed	
Aspotogan Consolidated Elementary	S 176 Boys washroom sink Right	11.0	0.9	Passed	
Aspotogan Consolidated Elementary	S 176 Boys washroom sink Middle	38.0	1.4	Passed	
Aspotogan Consolidated Elementary	S 176 Boys washroom sink Left	9.7	0.5	Passed	
Aspotogan Consolidated Elementary	S Near room 180 in hall fountain	10.0	0.5	Passed	
Aspotogan Consolidated Elementary	S 180 fan room (top of steps)	29.0	41.0	Exceeds Limit	Signage to be added to instruct handwashing only
Aspotogan Consolidated Elementary	S 177 Janitor closet tap	7.0	2.3	Passed	
Aspotogan Consolidated Elementary	S 179 Girls washroom Right	11.0	-	Passed	
Aspotogan Consolidated Elementary	S 179 Girls washroom Middle	9.8	0.7	Passed	
Aspotogan Consolidated Elementary	S 179 Girls washroom Left	14.0	1.3	Passed	
Aspotogan Consolidated Elementary	S 138 Classroom sink	44.0	3.6	Passed	
Aspotogan Consolidated Elementary	S 139 Classroom sink	11.0	1.5	Passed	
Aspotogan Consolidated Elementary	S 147 counter sink in storage room off	19.0	8.6	Exceeds Limit	Signage to be added to instruct handwashing only
Aspotogan Consolidated Elementary	S 151 sick room sink	20.0	0.8	Passed	
Aspotogan Consolidated Elementary	S 152 washroom sink	12.0	0.8	Passed	
Aspotogan Consolidated Elementary	S 102 classroom sink	12.0	1.7	Passed	
Aspotogan Consolidated Elementary	S 104 washroom sink	12.0	-	Passed	
Aspotogan Consolidated Elementary	S 103 classroom sink	11.0	0.8	Passed	

Aspotogan Consolidated Elementary S	Near 107 hallway fountain	9.5	-	Passed	
Aspotogan Consolidated Elementary S	108 classroom sink	11.0	0.5	Passed	
Aspotogan Consolidated Elementary S	109 washroom sink	14.0	-	Passed	
Aspotogan Consolidated Elementary S	110 classroom sink	11.0	0.7	Passed	
Aspotogan Consolidated Elementary S	166 Janitor's sink	36.0	3.2	Passed	
Aspotogan Consolidated Elementary S	167 washroom sink	23.0	-	Passed	
Aspotogan Consolidated Elementary S	115 near dishwasher - left	23.0	0.6	Passed	
Aspotogan Consolidated Elementary S	115 middle of kitchen	12.0	1.2	Passed	
Aspotogan Consolidated Elementary S	126 in hall water fountain	11.0	-	Passed	
Aspotogan Consolidated Elementary S	Near 107 hallway fountain	510.0	2.8	Passed	
Aspotogan Consolidated Elementary S	126 in hall water fountain	2.6	-	Passed	
Bayview Community School	Rm 103 Counter Sink	220.0	3.2	Passed	
Bayview Community School	Office Meeting Room	95.0		Passed	
Bayview Community School	Staff Rm Counter Sink	61.0	1.3	Passed	
Bayview Community School	Fountain by Gym	51.0		Passed	
Bayview Community School	Kitchen Rm 163 Counter Sink Right	38.0		Passed	
Bayview Community School	Kitchen Rm 163 Hand Wash Sink	73.0		Passed	
Bayview Community School	Rm 102 Counter Sink	87.0	1.6	Passed	
Bayview Community School	Fountain near 137	34.0		Passed	
Bayview Community School	Upstairs Fountain	26.0		Passed	
Bayview Community School	Rm 201 Family Studies Right	45.0	1.7	Passed	
Bayview Community School	Rm 201 Family Studies Middle	60.0	1.0	Passed	
Bayview Community School	Rm 201 Family Studies Middle	57.0	1.1	Passed	
Bayview Community School	Rm 201 Family Studies Left	71.0	0.7	Passed	
Bayview Community School	Office Washroom	30.0	0.9	Passed	
Bayview Community School	Rm 113 Counter Sink	260.0	44.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Rm 114 Counter Sink	67.0	1.4	Passed	
Bayview Community School	Staff Rm 115 Washroom Right	97.0	0.8	Passed	
Bayview Community School	Staff Rm 115 Washroom Left	100.0	0.9	Passed	
Bayview Community School	Girls Washroom Near 115 Sink Right	230.0	1.5	Passed	
Bayview Community School	Girls Washroom Near 115 Sink Middl	290.0	140.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Girls Washroom Near 115 Sink Left	100.0	0.9	Passed	
Bayview Community School	Rm 150 Jan Mop Sink	73.0	-	Passed	
Bayview Community School	Boys Washroom Sink Right	86.0	-	Passed	

Bayview Community School	Boys Washroom Sink Left	87.0	1.0	Passed	
Bayview Community School	Gym Office Right	110.0	340.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Gym Office Left	100.0	1.2	Passed	
Bayview Community School	Girls Change Rm 156 Right	50.0	-	Passed	
Bayview Community School	Girls Change Rm 156 Left	74.0	1.5	Passed	
Bayview Community School	Boys Change Rm 157 Right	110.0	0.7	Passed	
Bayview Community School	Boys Change Rm 157 Left	92.0	8.1	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Rm 156 Music Rm Sink	61.0	2.1	Passed	
Bayview Community School	Rm 164 Counter Sink	45.0	0.7	Passed	
Bayview Community School	Kitchen Rm 163 Counter Sink Dishes	30.0	2.3	Passed	
Bayview Community School	Rm 120 Library Storage Rm	660.0	490.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Rm 101 Bathroom Sink	49.0	1.4	Passed	
Bayview Community School	Rm 102 Bathroom Sink in Rm 127	61.0	-	Passed	
Bayview Community School	Rm 104 Bathroom Sink	58.0	0.8	Passed	
Bayview Community School	Rm 104 Counter Sink	41.0	0.9	Passed	
Bayview Community School	Rm 103 Bathroom Sink	77.0	-	Passed	
Bayview Community School	Rm 106 Counter Sink	45.0	0.9	Passed	
Bayview Community School	Rm 105 Bathroom Sink	50.0	-	Passed	
Bayview Community School	Rm 105 Counter Sink	48.0	1.8	Passed	
Bayview Community School	Boys Washroom Across Fr 137 Right	63.0	1.5	Passed	
Bayview Community School	Boys Washroom Across Fr 137 Middl	100.0	20.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Boys Washroom Across Fr 137 Middl	190.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Boys Washroom Across Fr 137 Left	50.0	2.8	Passed	
Bayview Community School	Girls Washroom near 137 Sink Right	71.0	0.9	Passed	
Bayview Community School	Girls Washroom near 137 Sink Middl	93.0	1.8	Passed	
Bayview Community School	Girls Washroom near 137 Sink Middl	75.0	0.7	Passed	
Bayview Community School	Girls Washroom near 137 Sink Left	73.0	0.5	Passed	
Bayview Community School	Rm 107 Counter Sink	450.0	33.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Rm 108 Counter Sink	49.0	6.3	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Rm 109 Counter	240.0	5.9	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Rm 110 Counter Sink	61.0	2.7	Passed	
Bayview Community School	Rm111 Counter Sink	130.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Rm 112 Counter Sink	61.0	1.1	Passed	
Bayview Community School	Rm 232 Bathroom Sink	67.0	1.9	Passed	

Bayview Community School	Rm 231 Jan Mop Sink	79.0	26.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Rm 233 Staff Washroom Sink	170.0	72.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Washroom next to Rm 201	95.0	1.8	Passed	
Bayview Community School	Rm 204 Counter Sink	62.0	2.1	Passed	
Bayview Community School	Rm 203 Counter Sink	49.0	2.0	Passed	
Bayview Community School	Rm 206 Counter Sink	70.0	1.9	Passed	
Bayview Community School	Rm 205 Counter Sink	96.0	1.7	Passed	
Bayview Community School	Rm 208 Counter Sink	150.0	3.8	Passed	
Bayview Community School	Rm 207 Counter Sink	70.0	1.4	Passed	
Bayview Community School	Boys Washroom Upstairs Right	69.0	1.0	Passed	
Bayview Community School	Boys Washroom Upstairs Middle	61.0	0.8	Passed	
Bayview Community School	Boys Washroom Upstairs Left	61.0	0.8	Passed	
Bayview Community School	Girls Washroom Upstairs Right	97.0	7.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Girls Washroom Upstairs Middle	100.0	5.5	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Girls Washroom Upstairs Left	98.0	6.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bayview Community School	Rm 214 Counter Sink	59.0	1.1	Passed	
Bayview Community School	Rm 216 Counter Sink	210.0	1.5	Passed	
Bayview Community School	Rm 215 Counter Sink	130.0	1.9	Passed	
Bayview Community School	Rm 217 Counter Sink	220.0	1.4	Passed	
Bayview Community School	Rm 101 Counter Sink Pre Primary	5.3	1.4	Passed	
Bayview Community School	Fountain near 137	31.0	-	Passed	
Bayview Community School	Upstairs Fountain	64.0	-	Passed	
Bayview Community School	Rm 101 Counter Sink Pre Primary		3.1	Passed	
Big Tancook Elementary School	Student washroom (old crane)	25.0	21.0	Exceeds Limit	Signage to be added to instruct handwashing only
Big Tancook Elementary School	Teacher washroom(old crane)	160.0	86.0	Exceeds Limit	Signage to be added to instruct handwashing only
Big Tancook Elementary School	Small spout at kitchen sink (approx 2	2.2	-	Passed	
Big Tancook Elementary School	Drinking fountain	6.6	1.8	Passed	
Big Tancook Elementary School	Kitchen sink (regular tap) (old crane	1.7	-	Passed	
Bluenose Academy	117 Washroom	78.0	-	Passed	
Bluenose Academy	118 Classroom sink	89.0	-	Passed	
Bluenose Academy	120 Classroom sink	57.0	-	Passed	
Bluenose Academy	117 Classroom sink	85.0	-	Passed	
Bluenose Academy	121 Classroom sink	82.0	-	Passed	
Bluenose Academy	123 Classroom sink	68.0	-	Passed	

Bluenose Academy	114 Classroom sink	54.0	-	Passed	
Bluenose Academy	114A Bathroom sink	70.0	-	Passed	
Bluenose Academy	112 Classroom sink	50.0	-	Passed	
Bluenose Academy	112A Bathroom sink	120.0	-	Passed	
Bluenose Academy	124A Bathroom sink	100.0	-	Passed	
Bluenose Academy	132 Washroom (128A)	120.0	-	Passed	
Bluenose Academy	Near 132 fountain in hall upper	44.0	-	Passed	
Bluenose Academy	Near 132 fountain in hall lower	57.0	-	Passed	
Bluenose Academy	Main floor boys washroom Right	49.0	0.6	Passed	
Bluenose Academy	Main floor boys washroom Middle	48.0	0.7	Passed	
Bluenose Academy	Main floor boys washroom Left	50.0	-	Passed	
Bluenose Academy	111 Staff washroom sink	56.0	1.8	Passed	
Bluenose Academy	Main floor girls washroom Right	56.0	0.9	Passed	
Bluenose Academy	Main floor girls washroom Middle	54.0	0.5	Passed	
Bluenose Academy	Main floor girls washroom Left	53.0	0.5	Passed	
Bluenose Academy	103A Janitor's closet	120.0	5.3	Exceeds Limit	Signage to be added to instruct handwashing only
Bluenose Academy	Near 104 Lobby fountain	44.0	-	Passed	
Bluenose Academy	135.1 near dishwasher	62.0	0.7	Passed	
Bluenose Academy	135.1 near freezer	110.0	0.8	Passed	
Bluenose Academy	135.1 near stove	97.0	-	Passed	
Bluenose Academy	151 girls locker room	56.0	3.5	Passed	
Bluenose Academy	150 boys locker room	72.0	4.7	Passed	
Bluenose Academy	148 Staff gym washroom	150.0	0.8	Passed	
Bluenose Academy	137 set tub in music room	98.0	1.0	Passed	
Bluenose Academy	141 custodial room	96.0	1.1	Passed	
Bluenose Academy	142.1 wood lab	270.0	2.8	Passed	
Bluenose Academy	145 classroom sink	110.0	1.0	Passed	
Bluenose Academy	Boiler room sink	140.0	2.0	Passed	
Bluenose Academy	218 classroom sink	61.0	0.7	Passed	
Bluenose Academy	220 classroom sink	96.0	-	Passed	
Bluenose Academy	217A washer/dryer/laundry	49.0	1.0	Passed	
Bluenose Academy	216.2 hand wash	81.0	-	Passed	
Bluenose Academy	216.1 counter sinks	71.0	-	Passed	
Bluenose Academy	216.1 counter sinks	130.0	1.0	Passed	

Bluenose Academy	216.1 counter sinks	82.0	1.1	Passed	
Bluenose Academy	216.1 counter sinks	83.0	1.0	Passed	
Bluenose Academy	221 counter sink	72.0	-	Passed	
Bluenose Academy	223 counter sink	81.0	-	Passed	
Bluenose Academy	214 counter sink	110.0	1.5	Passed	
Bluenose Academy	212 counter sink	70.0	0.4	Passed	
Bluenose Academy	224 counter sink	86.0	0.5	Passed	
Bluenose Academy	226 counter sink	110.0	0.6	Passed	
Bluenose Academy	Near 203A hall fountain	40.0	-	Passed	
Bluenose Academy	Boys washroom 2nd floor Right	48.0	0.7	Passed	
Bluenose Academy	Boys washroom 2nd floor Middle	40.0	0.6	Passed	
Bluenose Academy	Boys washroom 2nd floor Left	40.0	0.6	Passed	
Bluenose Academy	210A Janitor's sink	520.0	34.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bluenose Academy	211 Staff washroom	59.0	2.3	Passed	
Bluenose Academy	Girls washroom 2nd Floor Right	46.0	0.6	Passed	
Bluenose Academy	Girls washroom 2nd Floor Middle	47.0	-	Passed	
Bluenose Academy	Girls washroom 2nd Floor Left	47.0	0.5	Passed	
Bluenose Academy	208 counter sink	120.0	-	Passed	
Bluenose Academy	208A staff washroom	150.0	-	Passed	
Bluenose Academy	204 Janitor's closet	60.0	2.2	Passed	
Bluenose Academy	202 washroom	160.0	2.6	Passed	
Bluenose Academy	201 Classroom sink on right	100.0	1.2	Passed	
Bluenose Academy	201 Classroom sink on left	100.0	1.2	Passed	
Bluenose Academy	Mechanical room set tub	160.0	7.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bluenose Academy	317A in back room in lab	47.0	1.3	Passed	
Bluenose Academy	317 Lab sink on right	150.0	0.5	Passed	
Bluenose Academy	317 Lab sink on middle	130.0	0.9	Passed	
Bluenose Academy	317 Lab sink on left	25.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bluenose Academy	317 Lab sink on window wall right	100.0	1.5	Passed	
Bluenose Academy	317 Lab sink on window wall middle	150.0	1.4	Passed	
Bluenose Academy	317 Lab sink on window wall left	120.0	3.6	Passed	
Bluenose Academy	Near 303A fountain 3rd floor hall	71.0	-	Passed	
Bluenose Academy	Boys washroom 3rd floor Right	53.0	1.0	Passed	
Bluenose Academy	Boys washroom 3rd floor Middle	51.0	0.9	Passed	

Bluenose Academy	Boys washroom 3rd floor Left	52.0	0.7	Passed	
Bluenose Academy	Custodian room	150.0	5.2	Exceeds Limit	Signage to be added to instruct handwashing only
Bluenose Academy	Staff washroom	61.0	3.9	Passed	
Bluenose Academy	Girls washroom 3rd floor Right	45.0	1.2	Passed	
Bluenose Academy	Girls washroom 3rd floor Middle	45.0	0.6	Passed	
Bluenose Academy	Girls washroom 3rd floor Left	48.0	0.6	Passed	
Bluenose Academy	307.1 Fan room	82.0	1.8	Passed	
Bluenose Academy	Near 132 fountain in hall upper	170.0	-	Passed	
Bridgewater Elementary School	Cafeteria Island Sink	190.0	3.0	Passed	
Bridgewater Elementary School	Cafeteria Hand Wash Sink	270.0	2.0	Passed	
Bridgewater Elementary School	Fountain near Rm 106	42.0		Passed	
Bridgewater Elementary School	Rm 109 Counter Sink Right	110.0		Passed	
Bridgewater Elementary School	Rm 109 Counter Sink Left	99.0		Passed	
Bridgewater Elementary School	Rm 110 Counter Sink	200.0	0.7	Passed	
Bridgewater Elementary School	Office Washroom Sink	110.0		Passed	
Bridgewater Elementary School	Fountain Near 104	38.0		Passed	
Bridgewater Elementary School	Fountain Near 203	41.0		Passed	
Bridgewater Elementary School	Rm 204 Counter Sink	110.0	2.1	Passed	
Bridgewater Elementary School	Learning Commons Fountain	69.0		Passed	
Bridgewater Elementary School	Fountain Near 308	52.0		Passed	
Bridgewater Elementary School	Fountain Near Rm 302	47.0		Passed	
Bridgewater Elementary School	Rm 200 Bathroom Sink	320.0	5.6	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Rm 200 Counter Sink	260.0	2.5	Passed	
Bridgewater Elementary School	Boiler Rm Mop Sink	99.0	-	Passed	
Bridgewater Elementary School	Boys Washroom Bottom Floor Right	610.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Boys Washroom Bottom Floor Middle	880.0	17.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Boys Washroom Bottom Floor Left	780.0	6.5	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	First Floor Jan Sink	73.0	1.1	Passed	
Bridgewater Elementary School	Staff Washroom First Floor Right	110.0	2.1	Passed	
Bridgewater Elementary School	Girls Washroom First Floor Right	1,600.0	18.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Girls Washroom First Floor Middle	3,100.0	40.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Girls Washroom First Floor Middle	880.0	7.9	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Girls Washroom First Floor Middle	1,700.0	31.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Girls Washroom First Floor Left	570.0	3.3	Passed	

Bridgewater Elementary School	Rm 105 Counter Sink	260.0	16.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Cafeteria Jan Closet Mop Sink	810.0	4.3	Passed	
Bridgewater Elementary School	Cafeteria Dish Sink Right	380.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Cafeteria Dish Sink Left	140.0	3.2	Passed	
Bridgewater Elementary School	Rm 106 Counter Sink	140.0	3.1	Passed	
Bridgewater Elementary School	Rm 109 Bathroom Sink Right	290.0	1.7	Passed	
Bridgewater Elementary School	Rm 109 Bathroom Sink Left	150.0	1.4	Passed	
Bridgewater Elementary School	Rm 110 Bathroom Sink Right	140.0	1.4	Passed	
Bridgewater Elementary School	Rm 110 Bathroom Sink Left	220.0	2.7	Passed	
Bridgewater Elementary School	Counter Sink Rm 111	530.0	360.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Rm 107 Counter Sink	200.0	2.3	Passed	
Bridgewater Elementary School	Rm 101 Counter Sink	450.0	5.0	Passed	
Bridgewater Elementary School	103 Counter Sink	290.0	3.9	Passed	
Bridgewater Elementary School	102 Counter Sink	360.0	1.2	Passed	
Bridgewater Elementary School	rm 202 Counter Sink	130.0	88.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Boys Second Floor Washroom Right	320.0	1.1	Passed	
Bridgewater Elementary School	Boys Second Floor Washroom Middle	530.0	8.2	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Boys Second Floor Washroom Middle	310.0	3.8	Passed	
Bridgewater Elementary School	Boys Second Floor Washroom Left	290.0	4.2	Passed	
Bridgewater Elementary School	Custodian #2 Jan Closet Mop Sink	130.0	3.2	Passed	
Bridgewater Elementary School	Second Floor Staff Washroom	92.0	0.9	Passed	
Bridgewater Elementary School	Girls Second Floor Washroom Right	350.0	2.4	Passed	
Bridgewater Elementary School	Girls Second Floor Washroom Middle	260.0	2.3	Passed	
Bridgewater Elementary School	Girls Second Floor Washroom Middle	420.0	4.0	Passed	
Bridgewater Elementary School	Girls Second Floor Washroom Left	440.0	2.6	Passed	
Bridgewater Elementary School	Rm 203 Counter Sink	440.0	86.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Custodial Sink Queen St. Lobby	590.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Washroom Sink Queen St. Lobby	330.0	1.4	Passed	
Bridgewater Elementary School	Gym Boys Bathroom Sink	300.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Gym Office Bathroom Sink	430.0	28.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Gym Girls Bathroom Sink	910.0	220.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Learning Commons Work Room	1,600.0	17.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Boys 3rd Floor Washrooms Right	110.0	-	Passed	
Bridgewater Elementary School	Boys 3rd Floor Washrooms Middle	140.0	0.9	Passed	

Bridgewater Elementary School	Boys 3rd Floor Washrooms Middle	730.0	9.7	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Boys 3rd Floor Washrooms Left	660.0	6.2	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Custodian #3 Mop Sink	280.0	3.9	Passed	
Bridgewater Elementary School	Staff Washroom First Floor Right	540.0	3.3	Passed	
Bridgewater Elementary School	Girls 3rd Floor Washroom Right	1,300.0	7.9	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Girls 3rd Floor Washroom Middle	780.0	5.2	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Girls 3rd Floor Washroom Middle	480.0	4.4	Passed	
Bridgewater Elementary School	Girls 3rd Floor Washroom Left	470.0	2.7	Passed	
Bridgewater Elementary School	Rm 307 Counter Sink	480.0	3.3	Passed	
Bridgewater Elementary School	Rm 308 Counter Sink	130.0	1.8	Passed	
Bridgewater Elementary School	Rm 309 Counter Sink	220.0	1.6	Passed	
Bridgewater Elementary School	Rm S Cook (Old Art Rm) Counter Sink	400.0	12.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Rm S Cook (Old Art Rm) Counter Sink	390.0	25.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Rm 301 Counter Sink	590.0	10.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Rm 306 Counter Sink	400.0	9.9	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Rm 302 Counter Sink	260.0	3.5	Passed	
Bridgewater Elementary School	Rm 303 Counter Sink	620.0	18.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Rm 305 Counter Sink	420.0	4.3	Passed	
Bridgewater Elementary School	Rm 304 Counter Sink	390.0	6.3	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Elementary School	Fountain near 104	64.0	3.2	Passed	
Bridgewater Elementary School	Learning Commons Fountain	80.0	-	Passed	
Bridgewater Junior High School	Staff Room Counter Sink	210.0	1.2	Passed	
Bridgewater Junior High School	Fountain near E125	100.0	-	Passed	
Bridgewater Junior High School	Rm E101 Hand Wash Sink Right	270.0	1.9	Passed	
Bridgewater Junior High School	Rm E101 2-Bay sink	230.0	2.0	Passed	
Bridgewater Junior High School	Rm E138 Office Counter Sink	120.0	3.3	Passed	
Bridgewater Junior High School	Fountain Near Rm 124	48.0	-	Passed	
Bridgewater Junior High School	Rm 104 Rm 105 Counter Sink	75.0	0.9	Passed	
Bridgewater Junior High School	Fountain Near E220	78.0		Passed	
Bridgewater Junior High School	RM E122 Closet E123 Sink	11,000.0	1,400.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E122 Laundry Tub	120.0	6.7	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E115 Mop Sink	910.0	3.9	Passed	
Bridgewater Junior High School	Rm E111 Mop Sink	200.0	5.4	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E110 Bathroom Sink	300.0	2.1	Passed	

Bridgewater Junior High School	Rm E109 Girls Washroom Right	310.0	4.8	Passed	
Bridgewater Junior High School	Rm E109 Girls Washroom Middle	300.0	1.1	Passed	
Bridgewater Junior High School	Rm E109 Girls Washroom Left	380.0	3.2	Passed	
Bridgewater Junior High School	Rm E125, Rm E127, Rm E126 Countertops	550.0	340.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Boys Washroom E107 Right	510.0	20.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Boys Washroom E107 Middle	380.0	2.1	Passed	
Bridgewater Junior High School	Boys Washroom E107 Left	340.0	8.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E101 Dish Wash Sink	120.0	3.1	Passed	
Bridgewater Junior High School	Rm E138 Office Washroom Sink	250.0	1.9	Passed	
Bridgewater Junior High School	Rm 123 Mop Sink	91.0	1.9	Passed	
Bridgewater Junior High School	Rm 124 Bathroom Sink	100.0	0.9	Passed	
Bridgewater Junior High School	Rm 136 Counter Sink Right	840.0	190.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 136 Counter Sink Left	1,100.0	43.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 119, Rm 118 Bathroom Sink	87.0	1.4	Passed	
Bridgewater Junior High School	Male Locker Room Bathroom Right	82.0	1.6	Passed	
Bridgewater Junior High School	Male Locker Room Bathroom Left	270.0	0.7	Passed	
Bridgewater Junior High School	Rm 104 Rm 106 bathroom Sink Right	330.0	2.4	Passed	
Bridgewater Junior High School	Rm 104 Rm 106 Bathroom Sink Left	75.0	1.0	Passed	
Bridgewater Junior High School	Rm E214 Counter Sink	47.0	0.7	Passed	
Bridgewater Junior High School	Rm E209 Jan Mop Sink	370.0	4.1	Passed	
Bridgewater Junior High School	Rm E208 Bathroom Sink	310.0	10.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E205 Girls Washroom Right	840.0	9.5	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E205 Girls Washroom Middle	640.0	5.9	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E205 Girls Washroom Left	450.0	3.8	Passed	
Bridgewater Junior High School	Boys Washroom near E220 Right	1,100.0	22.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Boys Washroom near E220 Middle	980.0	7.8	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Boys Washroom near E220 Left	1,000.0	6.8	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 E203 Counter Sink	1,900.0	550.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Right	160.0	41.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Middle	110.0	30.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Middle	190.0	100.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Middle	290.0	26.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Middle	110.0	110.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Middle	170.0	41.0	Exceeds Limit	Signage to be added to instruct handwashing only

Bridgewater Junior High School	Rm E202 Lab Counter Middle	170.0	43.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Middle	350.0	33.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Middle	200.0	65.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Middle	260.0	16.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Middle	140.0	21.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm E202 Lab Counter Middle	270.0	4.7	Passed	
Bridgewater Junior High School	Rm 201 Lab Sinks Counter Right	740.0	45.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 201 Lab Sinks Counter Left	120.0	1.5	Passed	
Bridgewater Junior High School	Rm 201 Lab Desk Sinks	3,300.0	35.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 201 Lab Desk Sinks	380.0	8.5	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 201 Lab Desk Sinks	910.0	49.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 201 Lab Desk Sinks	170.0	31.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 201 Front of Class "Cold" (left)	130.0	71.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Staff Room Bathroom E228 Sink	180.0	1.0	Passed	
Bridgewater Junior High School	Rm 201 Counter Sink Right	180.0	1.7	Passed	
Bridgewater Junior High School	Rm 201 Counter Sink Left	190.0	50.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 216 Counter Sink Middle	380.0	3.1	Passed	
Bridgewater Junior High School	Rm 216 Counter Sink Middle	160.0	1.5	Passed	
Bridgewater Junior High School	Rm 216 Counter Sink Left	110.0	2.1	Passed	
Bridgewater Junior High School	Rm 204 Counter Sink Right	240.0	17.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 204 Counter Sink Middle	300.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 204 Counter Sink Left	330.0	36.0	Exceeds Limit	Signage to be added to instruct handwashing only
Bridgewater Junior High School	Rm 209 Female Washroom Right	70.0	1.2	Passed	
Bridgewater Junior High School	Rm 209 Female Washroom Left	68.0	0.8	Passed	
Bridgewater Junior High School	Janitors Closet Mop Sink	69.0	2.6	Passed	
Bridgewater Junior High School	Rm 208 Boys Washroom Right	60.0	1.0	Passed	
Bridgewater Junior High School	Rm 208 Boys Washroom Left	79.0	1.9	Passed	
Bridgewater Junior High School	Washroom next to 205 Washroom Si	100.0	1.3	Passed	
Bridgewater Junior High School	Rm 216 Counter Sink Right	8.4	0.9	Passed	
Bridgewater Junior High School	Fountain near E125	98.0	-	Passed	
Bridgewater Junior High School	Rm 216 Counter Sink Right		1.7	Passed	
Chester Area Middle School	Rm 1233 Far Right Counter Sink	470.0	3.8	Passed	
Chester Area Middle School	Rm 1233 Counter Sink Middle	390.0	3.5	Passed	
Chester Area Middle School	Rm 1233 Counter Sink Middle	500.0	3.2	Passed	

Chester Area Middle School	Gym Fountain Near 1406	700.0	1.1	Passed	
Chester Area Middle School	Rm 1419 Hand Wash Sink	1,500.0	1.1	Passed	
Chester Area Middle School	Rm 1419 Counter Sink Left	780.0	2.8	Passed	
Chester Area Middle School	Fountain Across from Rm 1206	930.0		Passed	
Chester Area Middle School	Rm 1214 Kitchenette Counter Sink	430.0	0.5	Passed	
Chester Area Middle School	Connect Ctr (Old staff rm) Counter Si	390.0	2.0	Passed	
Chester Area Middle School	Fountain Upstairs near 2210	720.0		Passed	
Chester Area Middle School	Rm 1233 Counter Sink Left	15.0	1.3	Passed	
Chester Area Middle School	Rm 1230 Counter Sink	280.0	1.9	Passed	
Chester Area Middle School	Rm 1103 Office Washroom Sink	540.0	5.3	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 1233 Laundry Tub	750.0	4.5	Passed	
Chester Area Middle School	Rm 1235 Counter Sink Right	180.0	2.9	Passed	
Chester Area Middle School	Rm 1235 Counter Sink Left	160.0	3.3	Passed	
Chester Area Middle School	Rm 1237 Counter Sink	400.0	3.5	Passed	
Chester Area Middle School	Rm 1402 Bathroom Sink	400.0	3.5	Passed	
Chester Area Middle School	Rm 1404 Girls Locker Rm Sink	340.0	2.4	Passed	
Chester Area Middle School	Rm 1406 Jan. Mop Sink	270.0	8.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 1407 Boys Locker Room Sink	630.0	1.6	Passed	
Chester Area Middle School	Rm 1409 bathroom Sink	320.0	18.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 1411 Laundry Tub	320.0	4.5	Passed	
Chester Area Middle School	Rm 1420 Laundry Tub	480.0	400.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 1419 3 Bay Sink Cafeteria Dishes	300.0	3.7	Passed	
Chester Area Middle School	Male Washroom Main Floor Right	680.0	2.2	Passed	
Chester Area Middle School	Male Washroom Main Floor Middle	490.0	2.8	Passed	
Chester Area Middle School	Male Washroom Main Floor Left	580.0	2.6	Passed	
Chester Area Middle School	jan Room Mop Sink	600.0	9.4	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Female Washroom Main Floor Right	730.0	2.4	Passed	
Chester Area Middle School	Female Washroom Main Floor Middl	390.0	2.6	Passed	
Chester Area Middle School	Female Washroom Main Floor Left	570.0	1.7	Passed	
Chester Area Middle School	Rm 1214 bathroom Sink	650.0	1.8	Passed	
Chester Area Middle School	Connect Ctr (old staff rm) Washroom	480.0	6.8	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 2228 Lab Counter Sink Right	240.0	6.5	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 2228 Lab Counter Sink Middle	100.0	12.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 2228 Lab Counter Sink Middle	95.0	9.6	Exceeds Limit	Signage to be added to instruct handwashing only

Chester Area Middle School	Rm 2228 Lab Counter Sink Middle	280.0	6.5	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 2228 Lab Counter Sink Middle	370.0	12.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 2228 Lab Counter Sink Middle	240.0	6.9	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 2228 Lab Counter Sink Left	94.0	45.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 2228 Lab Counter Sink Front of C	450.0	28.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Male Washroom Upstairs Sink Right	560.0	4.0	Passed	
Chester Area Middle School	Male Washroom Upstairs Sink Middle	360.0	4.8	Passed	
Chester Area Middle School	Male Washroom Upstairs Sink Left	460.0	4.3	Passed	
Chester Area Middle School	Rm 2220 Jan Mop Sink	300.0	1.6	Passed	
Chester Area Middle School	Female Washroom Upstairs Right	430.0	8.1	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Female Washroom Upstairs Middle	620.0	4.6	Passed	
Chester Area Middle School	Female Washroom Upstairs Left	540.0	2.9	Passed	
Chester Area Middle School	Rm 2213 Staff Washroom	820.0	0.9	Passed	
Chester Area Middle School	Rm 1104 Washroom in Office	530.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 1233 Counter Sink Left	45.0	8.1	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 1233 Counter Sink Left	57.0	8.4	Exceeds Limit	Signage to be added to instruct handwashing only
Chester Area Middle School	Rm 1233 Counter Sink Left	43.0	2.8	Passed	
Chester District Elementary School	Fountain Near 104	410.0	1.1	Passed	
Chester District Elementary School	Water Fountain Left Near 120	660.0	3.3	Passed	
Chester District Elementary School	Water Fountain Right Near 122	760.0	3.9	Passed	
Chester District Elementary School	Rm 125 Washroom Sink Pre-Primary	1,400.0	290.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Office Back Rm Counter Sink	40.0	4.2	Passed	
Chester District Elementary School	Rm 111 Kitchen Sink (back Rm)	14.0	5.0	Passed	
Chester District Elementary School	Cafeteria Left 3 Bay Sink	77.0	4.5	Passed	
Chester District Elementary School	Rm 125 Washroom Sink Pre-Primary	50.0	5.9	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 146 Counter Sink Right	200.0	89.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 146 Counter Sink Left	73.0	91.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Boys Washroom Rm 102 Right	110.0	3.3	Passed	
Chester District Elementary School	Boys Washroom Rm 102 Left	110.0	5.2	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Janitors Mop Sink Rm 104	340.0	88.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 103 Counter Sink	200.0	25.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Washroom Sink in Rm 106	210.0	38.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Girls Washroom Rm 109 Right	110.0	4.0	Passed	
Chester District Elementary School	Girls Washroom Rm 109 Left	130.0	2.9	Passed	

Chester District Elementary School	Counter Sink Rm 111	60.0	37.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 111 bathroom Sink (back Rm)	150.0	49.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Gym Office Bathroom Sink	120.0	73.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Gym Boys Washroom (lockerroom) S	440.0	32.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Gym Girls Washroom (locker room) S	400.0	52.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 12A-4 Cafeteria Jan. Sink	270.0	300.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 12A-3 Cafeteria Bathroom Sink	530.0	130.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Cafeteria 3 Bay Sink Right Tap	74.0	50.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Cafeteria 3 Bay Sink Left Tap	4,200.0	970.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 117 Counter Sink	190.0	23.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 118 Womans Washroom	270.0	7.8	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 118 Mens Washroom	320.0	8.6	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 119 Jan. Mop Sink	460.0	190.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 120 Boys Washroom Right	230.0	2.9	Passed	
Chester District Elementary School	Rm 120 Boys Washroom Middle	230.0	3.2	Passed	
Chester District Elementary School	Rm 120 Boys Washroom Left	230.0	4.4	Passed	
Chester District Elementary School	Rm 122 Girls Sink Right	230.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 122 Girls Sink Middle	330.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 122 Girls Sink Left	280.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 123 Washroom Sink	320.0	17.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 125 Washroom Sink Pre-Primary	240.0	14.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 124 Counter Sink	120.0	9.6	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 128 Counter Sink	310.0	17.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 130 Counter Sink	190.0	9.1	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 127C Counter Sink	180.0	66.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 133 Counter Sink	270.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 135 Counter Sink	360.0	16.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Rm 118 Counter Sink	2.4	6.0	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Water Fountain Left Near 120	370.0	2.9	Passed	
Chester District Elementary School	Office Back Rm Counter Sink	48.0	3.6	Passed	
Chester District Elementary School	Rm 111 bathroom Sink (back Rm)	37.0	5.1	Exceeds Limit	Signage to be added to instruct handwashing only
Chester District Elementary School	Cafeteria Left 3 Bay Sink	43.0	2.1	Passed	
Chester District Elementary School	Rm 123 Counter Sink Pre Primary	33.0	4.3	Passed	
Chester District Elementary School	Rm 125 Counter Sink Pre Primary	22.0	3.3	Passed	

Chester District Elementary School	Rm 117 Counter Sink	4.2	1.6	Passed	
Chester District Elementary School	Rm 111 Kitchen Sink (back Rm)	43.0	2.0	Passed	
Chester District Elementary School	Rm 123 Counter Sink Pre Primary		4.6	Passed	
Chester District Elementary School	Rm 125 Counter Sink		4.7	Passed	
Dr. John C. Wickwire Academy	143 Cafeteria sink far right	850.0	3.3	Passed	
Dr. John C. Wickwire Academy	143 Cafeteria sink left of dishwasher	270.0	3.9	Passed	
Dr. John C. Wickwire Academy	143 Cafeteria handwash sink	810.0	27.0	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	137 Boiler room laundry sink	220.0	17.0	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	137 janitor sink in small room in boiler	390.0	3.8	Passed	
Dr. John C. Wickwire Academy	146 Girls washroom in lobby Right	340.0	1.2	Passed	
Dr. John C. Wickwire Academy	146 Girls washroom in lobby Middle	250.0	3.0	Passed	
Dr. John C. Wickwire Academy	146 Girls washroom in lobby Left	280.0	2.5	Passed	
Dr. John C. Wickwire Academy	147 Boys washroom Right	380.0	1.6	Passed	
Dr. John C. Wickwire Academy	147 Boys washroom Middle	350.0	1.3	Passed	
Dr. John C. Wickwire Academy	147 Boys washroom Left	330.0	1.2	Passed	
Dr. John C. Wickwire Academy	near 150 lobby fountain	230.0	-	Passed	
Dr. John C. Wickwire Academy	148 counter sink	680.0	1.4	Passed	
Dr. John C. Wickwire Academy	149 counter sink	590.0	2.0	Passed	
Dr. John C. Wickwire Academy	155 gym teacher's bathroom sink	870.0	24.0	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	159 music room counter sink	1,400.0	140.0	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	108 bathroom in office (to the right)	1,500.0	79.0	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	134 counter sink	700.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	131 bathroom sink	480.0	14.0	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	131 drinking fountain at sink	970.0	3.8	Passed	
Dr. John C. Wickwire Academy	131 counter sink	570.0	8.8	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	116 Washroom sink in staff room	290.0	0.7	Passed	
Dr. John C. Wickwire Academy	130 washroom sink	300.0	12.0	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	130 fountain at counter sink	610.0	1.4	Passed	
Dr. John C. Wickwire Academy	130 counter sink	610.0	5.7	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	near 118 first floor fountain	170.0	-	Passed	
Dr. John C. Wickwire Academy	118 washroom sink	390.0	1.5	Passed	
Dr. John C. Wickwire Academy	119 fountain at counter sink	550.0	1.4	Passed	
Dr. John C. Wickwire Academy	119 counter sink	320.0	5.0	Passed	
Dr. John C. Wickwire Academy	127 washroom sink	250.0	3.4	Passed	

Dr. John C. Wickwire Academy	127 fountain at counter sink	630.0	1.6	Passed	
Dr. John C. Wickwire Academy	127 counter sink	510.0	8.2	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	120 fountain at counter sink	490.0	1.2	Passed	
Dr. John C. Wickwire Academy	120 counter sink	520.0	4.4	Passed	
Dr. John C. Wickwire Academy	121 fountain at counter sink	760.0	2.0	Passed	
Dr. John C. Wickwire Academy	121 counter sink	550.0	5.7	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	222 girls washroom 2nd floor Right	230.0	1.0	Passed	
Dr. John C. Wickwire Academy	222 girls washroom 2nd floor Middle	240.0	0.8	Passed	
Dr. John C. Wickwire Academy	222 girls washroom 2nd floor Left	300.0	3.0	Passed	
Dr. John C. Wickwire Academy	223 Janitor's closet	960.0	9.2	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	224 Boys washroom 2nd floor Right	320.0	1.2	Passed	
Dr. John C. Wickwire Academy	224 Boys washroom 2nd floor Middle	360.0	1.4	Passed	
Dr. John C. Wickwire Academy	224 Boys washroom 2nd floor Left	350.0	1.3	Passed	
Dr. John C. Wickwire Academy	225 Laundry tub back right of room	440.0	10.0	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	near room 206 fountain in hall	140.0	-	Passed	
Dr. John C. Wickwire Academy	206 washroom sink	470.0	1.4	Passed	
Dr. John C. Wickwire Academy	207 washroom sink	510.0	29.0	Exceeds Limit	Signage to be added to instruct handwashing only
Dr. John C. Wickwire Academy	116 counter sink	96.0	4.3	Passed	
Dr. John C. Wickwire Academy	143 Cafeteria sink right of dishwashe	110.0	2.5	Passed	
Forest Heights Community School	Fountain in Gym Lobby	8.4	2.4	Passed	
Forest Heights Community School	Fountain Across From 140A	240.0	1.0	Passed	
Forest Heights Community School	Fountain by Rm 152	9.6	1.2	Passed	
Forest Heights Community School	Cafeteria Counter Sink	11.0	2.1	Passed	
Forest Heights Community School	Cafeteria Hand Wash Sink	99.0	14.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 228 Counter Sink	6.0		Passed	
Forest Heights Community School	Rm 249B Counter Sink Right	15.0	4.2	Passed	
Forest Heights Community School	Rm 249B Counter Sink Middle	23.0	3.0	Passed	
Forest Heights Community School	Rm 249B Counter Sink Middle	120.0	2.6	Passed	
Forest Heights Community School	Rm 249B Counter Sink Left	57.0	3.9	Passed	
Forest Heights Community School	Rm 244 Counter Sink	74.0		Passed	
Forest Heights Community School	Fountain Near Rm 244	190.0		Passed	
Forest Heights Community School	Girls Bottom Floor Rm 126 Right	28.0	2.1	Passed	
Forest Heights Community School	Girls Bottom Floor Rm 126 Middle	19.0	5.3	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Girls Bottom Floor Rm 126 Left	19.0	8.4	Exceeds Limit	Signage to be added to instruct handwashing only

Forest Heights Community School	Rm 125 Jan Closet Mop Sink	9.2	1.1	Passed	
Forest Heights Community School	Rm 123 Boys Bottom Floor Right	18.0	10.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 123 Boys Bottom Floor Middle	27.0	12.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 123 Boys Bottom Floor Left	7.8	7.6	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Staff room near Gym Lobby Sink	130.0	6.2	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 108 Girls Locker Rm Right	22.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 108 Girls Locker Rm Left	5.3	16.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 111 Gym Office Sink	16.0	15.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 112 Gym Office Sink	400.0	160.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 118 Boys Locker Rm Right	24.0	9.1	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 118 Boys Locker Rm Left	9.8	1.8	Passed	
Forest Heights Community School	Rm 103A Bathroom Sink	25.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Skilled Trades Lab Laundry Tub	11.0	-	Passed	
Forest Heights Community School	Rm 152 Jan Sink	14.0	2.2	Passed	
Forest Heights Community School	Rm 216 Girls Upstairs Washroom Rig	18.0	4.7	Passed	
Forest Heights Community School	Rm 216 Girls Upstairs Washroom Mic	11.0	3.6	Passed	
Forest Heights Community School	Rm 216 Girls Upstairs Washroom Lef	17.0	5.8	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 215 Jan Mop Sink	7.2	1.4	Passed	
Forest Heights Community School	Rm 213 Boys Upstairs Sink Right	10.0	4.5	Passed	
Forest Heights Community School	Rm 213 Boys Upstairs Sink Middle	19.0	4.9	Passed	
Forest Heights Community School	Rm 213 Boys Upstairs Sink Left	16.0	6.2	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 212 Bathroom Sink	110.0	0.9	Passed	
Forest Heights Community School	209A Counter Sink	11.0	7.1	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Cafeteria Dishes Wash Sink	190.0	0.9	Passed	
Forest Heights Community School	Cafeteria Cutlery Sink	14.0	0.8	Passed	
Forest Heights Community School	Rm 218 Lab Sink Right	1,100.0	22.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 218 Lab Sink Middle	4,100.0	62.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 218 Lab Sink Middle	14.0	1.1	Passed	
Forest Heights Community School	Rm 218 Lab Sink Middle	9.7	1.0	Passed	
Forest Heights Community School	Rm 218 Lab Sink Middle	70.0	3.0	Passed	
Forest Heights Community School	Rm 218 Lab Sink Middle	46.0	3.2	Passed	
Forest Heights Community School	Rm 218 Lab Sink Middle	13.0	-	Passed	
Forest Heights Community School	Rm 218 Lab Sink Middle	5.2	-	Passed	
Forest Heights Community School	Rm 218 Lab Sink Left	83.0	2.7	Passed	

Forest Heights Community School	Prep Room Counter Sink	5,000.0	33.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 226 Counter Sink Right	17.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 226 Counter Sink Left	10.0	1.2	Passed	
Forest Heights Community School	Rm 227 Lab Sink Front of Class Right	19.0	4.6	Passed	
Forest Heights Community School	Rm 227 Lab Sink Front of Class Left	45.0	4.1	Passed	
Forest Heights Community School	Rm 227 Back Lab Counter Sink Right	2,700.0	64.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 227 Back Lab Counter Sink Left	1,200.0	83.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 228 Bathroom Sink	19.0	9.8	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 231A Counter Sink Right	38.0	7.5	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 231A Counter Sink Left	22.0	5.5	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 235 Counter Sink Right	23.0	4.0	Passed	
Forest Heights Community School	Rm 235 Counter Sink Left	29.0	18.0	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Rm 238 Jan Room Mop Sink	12.0	0.5	Passed	
Forest Heights Community School	Rm 244 Bathroom 241	6.1	-	Passed	
Forest Heights Community School	Rm 244 Bathroom 243	14.0	4.6	Passed	
Forest Heights Community School	Office Bathroom Sink	73.0	6.8	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Heights Community School	Water Fountain Near Rm 227	8.4	-	Passed	
Forest Heights Community School	Fountain Across From 140A	72.0	1.3	Passed	
Forest Heights Community School	Fountain by Rm 152	42.0	2.6	Passed	
Forest Heights Community School	Water Fountain Near Rm 227	13.0	-	Passed	
Forest Heights Community School	Fountain near rm 244	12.0	-	Passed	
Forest Heights Community School	Office Counter Sink	8.3	0.8	Passed	
Forest Heights Community School	Fountain In Cafeteria		2.4	Passed	
Forest Heights Community School	Fountain In Cafeteria	54.0	2.4	Passed	
Greenfield Elementary School	Mrs. S. Hebrang Janitor's closet	910.0	1.3	Passed	
Greenfield Elementary School	Staff room counter sink	590.0	1.0	Passed	
Greenfield Elementary School	Washroom sink	1,800.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
Greenfield Elementary School	Mrs. Uhlman counter sink	410.0	2.8	Passed	
Greenfield Elementary School	Girls Washroom Right	790.0	4.4	Passed	
Greenfield Elementary School	Girls Washroom Middle	690.0	1.0	Passed	
Greenfield Elementary School	Girls Washroom Left	1,000.0	7.7	Exceeds Limit	Signage to be added to instruct handwashing only
Greenfield Elementary School	Multi-purpose room counter sink	1,500.0	0.6	Passed	
Greenfield Elementary School	Boy's washroom Right	1,700.0	7.5	Exceeds Limit	Signage to be added to instruct handwashing only
Greenfield Elementary School	Boy's washroom Middle	610.0	0.8	Passed	

Greenfield Elementary School	Boy's washroom Left	640.0	-	Passed	
Greenfield Elementary School	Mr. C. Snyder counter sink	600.0	1.6	Passed	
Greenfield Elementary School	Multi-purpose room counter sink	400.0	0.9	Passed	
Hebbville Academy	Fountain in Gym Entrance	180.0		Passed	
Hebbville Academy	Rm 143 Counter Sink	130.0	0.7	Passed	
Hebbville Academy	Rm 146 Counter Sink Right	150.0	1.9	Passed	
Hebbville Academy	Rm 146 Counter Sink Middle	190.0	3.8	Passed	
Hebbville Academy	Rm 146 Counter Sink Middle	220.0	3.5	Passed	
Hebbville Academy	Rm 146 Counter Sink Left	180.0	2.7	Passed	
Hebbville Academy	Rm 123 Counter Sink	160.0	2.1	Passed	
Hebbville Academy	Fountain near 177	160.0	2.2	Passed	
Hebbville Academy	Kitchen Rm 184 Hand Wash Sink	51.0	2.5	Passed	
Hebbville Academy	Kithcen Rm 184 Single Sink	85.0	2.1	Passed	
Hebbville Academy	Fountain near 223	3,500.0	2.9	Passed	
Hebbville Academy	Fountain Near Rm 240	130.0	-	Passed	
Hebbville Academy	Kitchen Rm 184 Island Sink	55.0	1.3	Passed	
Hebbville Academy	Boiler Room Laundry Tub	190.0	7.3	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 155 Jan Mop Sink	320.0	22.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 155 Bathroom Sink	220.0	0.5	Passed	
Hebbville Academy	Rm Jan Sink	1,100.0	110.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 164 Girls Locker Room Right	120.0	1.3	Passed	
Hebbville Academy	Rm 167 Gym Office Bathroom Sink	100.0	8.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 168 Gym Office Bathroom Sink	160.0	17.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Boys Locker Room 170 Sink Right	170.0	1.2	Passed	
Hebbville Academy	Boys Locker Room 170 Sink Left	63.0	0.7	Passed	
Hebbville Academy	Rm 147 Laundry Tub	64.0	49.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Staff Washroom near Rm 140 Sink	110.0	1.5	Passed	
Hebbville Academy	Rm 129 Girls Washroom Sink Right	82.0	10.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 129 Girls Washroom Sink Middle	100.0	4.5	Passed	
Hebbville Academy	Rm 129 Girls Washroom Sink Middle	110.0	2.7	Passed	
Hebbville Academy	Rm 129 Girls Washroom Sink Left	91.0	1.2	Passed	
Hebbville Academy	Rm 130 Jan Mop Sink	82.0	-	Passed	
Hebbville Academy	Rm 128 Boys Washroom Sink Right	70.0	1.6	Passed	
Hebbville Academy	Rm 128 Boys Washroom Sink Middle	76.0	-	Passed	

Hebbville Academy	Rm 128 Boys Washroom Sink Middle	81.0	5.8	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 128 Boys Washroom Sink Left	72.0	3.4	Passed	
Hebbville Academy	Rm 116 Lab Counter Sinks	34.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 116 Lab Counter Sinks	42.0	16.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 116 Lab Counter Sinks	83.0	7.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 116 Lab Counter Sinks	42.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 116 Lab Sink at Front of Class	99.0	22.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 111 Bathroom 113 Sink	170.0	0.8	Passed	
Hebbville Academy	Rm 123 Bathroom 119	78.0	0.6	Passed	
Hebbville Academy	Rm 177 Boys Washroom Sink Right	99.0	0.6	Passed	
Hebbville Academy	Rm 177 Boys Washroom Sink Middle	120.0	2.3	Passed	
Hebbville Academy	Rm 177 Boys Washroom Sink Left	160.0	0.7	Passed	
Hebbville Academy	Kitchen Rm 184 3 Bay Sink Dish	64.0	3.6	Passed	
Hebbville Academy	Kitchen Rm 184 Pre Wash Sink Dish	1,800.0	52.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 175 Girls Washroom Sink Right	110.0	5.3	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 175 Girls Washroom Sink Middle	180.0	1.4	Passed	
Hebbville Academy	Rm 175 Girls Washroom Sink Middle	120.0	4.4	Passed	
Hebbville Academy	Rm 175 Girls Washroom Sink Left	160.0	0.9	Passed	
Hebbville Academy	Rm 173 Music Counter Sink Right	87.0	220.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 173 Music Counter Sink Left	1,100.0	340.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 234 Laundry Tub (in back rm)	67.0	130.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 228A Laundry Tub	340.0	160.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 223 Washrooms (left of Fountain	96.0	3.4	Passed	
Hebbville Academy	Rm 222 Washroom (right of Fountair	100.0	-	Passed	
Hebbville Academy	Rm 216 Science Counter Sink Right	120.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 216 Science Counter Sink Middle	140.0	26.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 216 Science Counter Sink Middle	160.0	16.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 216 Science Counter Sink Left	650.0	36.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 213 Girls Washroom Right	150.0	5.9	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 213 Girls Washroom Middle	96.0	1.7	Passed	
Hebbville Academy	Rm 213 Girls Washroom Middle	120.0	3.6	Passed	
Hebbville Academy	Rm 213 Girls Washroom Left	84.0	1.4	Passed	
Hebbville Academy	Fountain by Rm 213	180.0	2.9	Passed	
Hebbville Academy	Rm 202 Boys Washroom Right	220.0	4.4	Passed	

Hebbville Academy	Rm 202 Boys Washroom Middle	130.0	4.4	Passed	
Hebbville Academy	Rm 202 Boys Washroom Left	120.0	1.1	Passed	
Hebbville Academy	Rm 201A Laundry Sink	240.0	110.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Rm 244 Counter Sink	120.0	-	Passed	
Hebbville Academy	Rm 242 Jan Mop Sink	170.0	15.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Academy	Kitchen Rm 184 Island Sink	55.0	1.3	Passed	
Hebbville Academy	Fountain near 223	120.0	0.5	Passed	
Hebbville Academy	Fountain near rm 240	270.0	0.7	Passed	
Hebbville Academy	Fountain in Gym Entrance	330.0	1.9	Passed	
Hebbville Academy	Fountain next to rm 129	160.0	0.7	Passed	
Hebbville Academy	Fountain near 223		1.4	Passed	
Hebbville Elementary	Fountain in Hall Across fr Rm 125	2.5		Passed	
Hebbville Elementary	Rm 125 Counter Sink Pre Primary	1.7		Passed	
Hebbville Elementary	Staff Room Sink	28.0	2.7	Passed	
Hebbville Elementary	Autism portable bathroom	3.5	3.5	Passed	
Hebbville Elementary	Janitors Mop Sink in Gym	6.8	1.9	Passed	
Hebbville Elementary	Rm 126 Boys Washroom Sink Right	12.0	1.5	Passed	
Hebbville Elementary	Rm 126 Boys Washroom Sink Middle	9.9	0.9	Passed	
Hebbville Elementary	Rm 126 Boys Washroom Sink Middle	12.0	1.4	Passed	
Hebbville Elementary	Rm 126 Boys Washroom Sink Left	13.0	1.4	Passed	
Hebbville Elementary	Rm 128 Staff Washroom Sink	26.0	1.4	Passed	
Hebbville Elementary	Rm 104 Staff Washroom Sink	49.0	12.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Elementary	Rm 106 Primary Washroom Sink	140.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Elementary	Girls Washroom Sink Right	44.0	0.7	Passed	
Hebbville Elementary	Girls Washroom Sink Middle	31.0	1.3	Passed	
Hebbville Elementary	Girls Washroom Sink Middle	14.0	1.8	Passed	
Hebbville Elementary	Girls Washroom Sink Left	23.0	1.2	Passed	
Hebbville Elementary	Rm 112 Janitors Mop Sink	45.0	-	Passed	
Hebbville Elementary	Middle level connect ctr. (right side t	19.0	19.0	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Elementary	Middle level connect ctr. (right side k	7.2	7.2	Exceeds Limit	Removed, out of service
Hebbville Elementary	Middle level connect ctr. (left side ba	6.8	6.8	Exceeds Limit	Signage to be added to instruct handwashing only
Hebbville Elementary	Middle level connect ctr. (Left side ki	3.9	3.9	Passed	
Hebbville Elementary	Fountain in Hall Across fr Rm 125	9.8	-	Passed	
Liverpool Regional High School	Cafeteria Counter Sink Right	140.0	5.2	Exceeds Limit	Faucet to be decommissioned, remediated, and re

Liverpool Regional High School	Cafeteria Counter Sink Left	580.0	300.0	Exceeds Limit	Faucet to be decommissioned, remediated, and re
Liverpool Regional High School	Main Crush Water Fountain	140.0	4.9	Passed	
Liverpool Regional High School	Rm 226 Counter Sink Resource	6.2	0.9	Exceeds Limit	Faucet to be decommissioned, remediated, and re
Liverpool Regional High School	104 - Counter Sink Resource	260.0	3.8	Passed	
Liverpool Regional High School	Cafeteria Counter Sink Right	180.0	1.3	Passed	
Liverpool Regional High School	Cafeteria counter sink left, hand wasl	310.0	190.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 226 Counter Sink closest to door	17.0	1.3	Passed	
Liverpool Regional High School	116-Bathroom sink	150.0	1.1	Passed	
Liverpool Regional High School	Near 117- Bathroom Sink	65.0	2.6	Passed	
Liverpool Regional High School	Near 116 - Bathroom Sink	54.0	1.0	Passed	
Liverpool Regional High School	146 - Janitor's sink	14.0	2.4	Passed	
Liverpool Regional High School	Boys Main Floor Right	140.0	2.5	Passed	
Liverpool Regional High School	Boys Main Floor Middle	94.0	0.9	Passed	
Liverpool Regional High School	Boys Main Floor Left	43.0	2.6	Passed	
Liverpool Regional High School	Girls Main Floor Right	110.0	2.2	Passed	
Liverpool Regional High School	Girls Main Floor Middle	180.0	1.7	Passed	
Liverpool Regional High School	Girls Main Floor Left	1,330.0	1.8	Passed	
Liverpool Regional High School	Rm 141 Counter Sink Right	91.0	250.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 141 Counter Sink Left	100.0	79.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 142 Counter Sink	63.0	5.8	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 159 Counter Sink	190.0	30.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 148 Bathroom Sink	68.0	1.4	Passed	
Liverpool Regional High School	Boys Locker Room Right	93.0	0.6	Passed	
Liverpool Regional High School	Boys Locker Room Left	180.0	-	Passed	
Liverpool Regional High School	Girls Locker Room Right	240.0	3.4	Passed	
Liverpool Regional High School	Girls Locker Room Left	96.0	1.6	Passed	
Liverpool Regional High School	Rm 155 Bathroom Sink	190.0	5.6	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Janitor's Sink - Rm 221	62.0	2.4	Passed	
Liverpool Regional High School	Upstairs Boys Bathroom Right	120.0	1.0	Passed	
Liverpool Regional High School	Upstairs Boys Bathroom Middle	54.0	0.6	Passed	
Liverpool Regional High School	Upstairs Boys Bathroom Left	25.0	0.6	Passed	
Liverpool Regional High School	Girls Upstairs bathroom Right	140.0	2.3	Passed	
Liverpool Regional High School	Girls Upstairs Bathroom Middle	190.0	7.8	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Girls Upstairs Bathroom Left	61.0	1.5	Passed	

Liverpool Regional High School	Chemistry Lab Storage (222)	840.0	380.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 222 Chem Lab Front of Class	280.0	54.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 222 Chem Lab Right	300.0	21.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 222 Chem Lab Middle	470.0	210.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 222 Chem Lab Middle	120.0	120.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 222 Chem Lab Middle	160.0	48.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 222 Chem Lab Middle	220.0	68.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 222 Chem Lab Middle	2,600.0	830.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 222 Chem Lab Left	230.0	30.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 223 Biology Right	150.0	40.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 223 Biology Middle	130.0	25.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 223 Biology Middle	310.0	71.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 223 Biology Middle	370.0	170.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 223 Biology Middle	420.0	95.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 223 Biology Left	350.0	92.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 231 Science Lab Right	80.0	110.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 231 Science Lab Middle	78.0	87.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 231 Science Lab Left	280.0	260.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Rm 227 Art Sink	210.0	68.0	Exceeds Limit	Signage to be added to instruct handwashing only
Liverpool Regional High School	Upstairs Crush Fountain	63.0	2.2	Passed	
Liverpool Regional High School	105 counter sink resource	13.0	0.6	Passed	
Liverpool Regional High School	Rm 226 Counter Sink Resource	11.0	1.5	Passed	
Liverpool Regional High School	105 - Counter Sink Resource		3.2	Passed	
Liverpool Regional High School	Rm 226 Counter Sink Resource		3.1	Passed	
Liverpool Regional High School	Cafeteria counter sink left, hand wash sink		6.5	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Elementary School	Cafeteria Hand Wash Sink Left	12.0		Passed	
New Germany Elementary School	Downstairs Fountain	44.0		Passed	
New Germany Elementary School	Pre Primary Counter Sink	16.0		Passed	
New Germany Elementary School	Pre Primary Counter Sink	40.0		Passed	
New Germany Elementary School	Upstairs Fountain	0.9		Passed	
New Germany Elementary School	Staffroom Counter Sink	2,300.0	1.8	Passed	
New Germany Elementary School	Cafeteria Counter Sink Right	14.0		Passed	
New Germany Elementary School	Boiler Rm Jan. Mop Sink	29.0	30.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Elementary School	Janitors Closet Downstairs	3.3	1.6	Passed	

New Germany Elementary School	Downstairs Boys Washroom Sink Righ	28.0	1.2	Passed	
New Germany Elementary School	Downstairs Boys Washroom Sink Mic	37.0	-	Passed	
New Germany Elementary School	Downstairs Boys Washroom Sink Left	22.0	-	Passed	
New Germany Elementary School	Downstairs Girls Washroom Sink Righ	23.0	0.6	Passed	
New Germany Elementary School	Downstairs Girls Washroom Sink Mid	37.0	0.9	Passed	
New Germany Elementary School	Downstairs Girls Washroom Sink Left	71.0	1.2	Passed	
New Germany Elementary School	Pre Primary Bathroom Sink Right	9.9	-	Passed	
New Germany Elementary School	Pre Primary Bathroom Sink Left	55.0	-	Passed	
New Germany Elementary School	Staff Washroom Left of Office	6.6	0.6	Passed	
New Germany Elementary School	Custodial Rm Across From Office	2.4	-	Passed	
New Germany Elementary School	Staff Washroom to the Right of Offic	4.9	-	Passed	
New Germany Elementary School	Upstairs Boys Washroom Sink Right	36.0	2.2	Passed	
New Germany Elementary School	Upstairs Boys Washroom Sink Middle	31.0	1.4	Passed	
New Germany Elementary School	Upstairs Boys Washroom Sink Middle	32.0	4.3	Passed	
New Germany Elementary School	Upstairs Boys Washroom Sink Left	37.0	6.1	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Elementary School	Upstairs Girls Washroom Sink Right	40.0	2.0	Passed	
New Germany Elementary School	Upstairs Girls Washroom Sink Middle	46.0	2.3	Passed	
New Germany Elementary School	Upstairs Girls Washroom Sink Middle	33.0	1.6	Passed	
New Germany Elementary School	Upstairs Girls Washroom Sink Left	25.0	1.1	Passed	
New Germany Elementary School	Bus Drivers Washroom in Garage	5.3	2.6	Passed	
New Germany Elementary School	Shop Laundry Tub in Garage	21.0	4.4	Passed	
New Germany Elementary School	Shop Washroom in Garage	9.6	3.1	Passed	
New Germany Elementary School	Staffroom Counter Sink	360.0	3.7	Passed	
New Germany Rural High School	Upstairs Fountain Across fr 303	230.0	0.7	Passed	
New Germany Rural High School	Upstairs Fountain Across fr 307	88.0		Passed	
New Germany Rural High School	Downstairs Fountain Across Fr. Rm 11	150.0	0.6	Passed	
New Germany Rural High School	Old Porcelain Fountain in Hall near 21	160.0	4.2	Passed	
New Germany Rural High School	Main Lobby Fountain	110.0		Passed	
New Germany Rural High School	Cafeteria Island Sink	270.0	1.4	Passed	
New Germany Rural High School	Cafeteria Hand Wash Sink	680.0	5.8	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Old Porcelain Fountain	180.0	1.8	Passed	
New Germany Rural High School	Rm 303 Counter Sink	80.0	1.0	Passed	
New Germany Rural High School	Boiler Rm Mop Sink	370.0	3.3	Passed	
New Germany Rural High School	Woodshop (through 107) Counter Sir	220.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only

New Germany Rural High School	Rm 107 Counter Sinks Right	570.0	9.6	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Rm 107 Counter Sinks Middle	410.0	710.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Rm 107 Counter Sinks Middle	150.0	33.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Rm 107 Counter Sinks Middle	100.0	7.9	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Rm 107 Counter Sinks Left	300.0	15.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Visual Arts Janitors Closet	400.0	3.1	Passed	
New Germany Rural High School	Visual Arts Counter Sink	370.0	3.2	Passed	
New Germany Rural High School	Girls Locker Room	220.0	8.2	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Girls Locker Room Bathroom	95.0	7.3	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Boys Locker Rm Right	170.0	19.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Boys Locker Rm left	150.0	7.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Downstairs Jan Rm #1 Mop Sink	220.0	7.8	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Rm 209 Lab Sinks	240.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Start at Front of Room	190.0	7.8	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Finish Rear Door	270.0	9.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		320.0	20.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		400.0	27.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		220.0	31.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		450.0	78.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		180.0	16.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		210.0	4.2	Passed	
New Germany Rural High School		180.0	4.7	Passed	
New Germany Rural High School		160.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		200.0	22.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		250.0	21.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		260.0	23.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		200.0	14.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School		250.0	35.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Rm 209 Sink Closest to Door	190.0	3.8	Passed	
New Germany Rural High School	Rm 208 Counter Sink on Right	360.0	24.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Rm 208 Counter Sink on Left	82.0	98.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Custodial rm Across fr rm 206	51.0	5.2	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Main Floor Girls Washroom Right	510.0	6.3	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Main Floor Girls Washroom Middle	180.0	2.5	Passed	

New Germany Rural High School	Main Floor Girls Washroom Left	170.0	3.1	Passed	
New Germany Rural High School	Main Floor Girls Staff Washroom Sink	530.0	19.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Main Floor Boys Staff Washroom Sink	82.0	3.1	Passed	
New Germany Rural High School	Main Floor Boys Washroom Right	90.0	5.8	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Main Floor Boys Washroom Middle	79.0	7.7	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Main Floor Boys Washroom Left	120.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Gym Office (in Gym) Bathroom Sink	210.0	5.0	Passed	
New Germany Rural High School	Office Staff Washroom	250.0	3.7	Passed	
New Germany Rural High School	Music Rm Counter Sink	210.0	2.2	Passed	
New Germany Rural High School	Single Washroom (left) Sink	200.0	3.3	Passed	
New Germany Rural High School	Single Washroom (Right) Sink	200.0	8.4	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Jan Closet in Cafeteria	200.0	12.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Cafeteria Dish Sprayer Dishes	96.0	1.6	Passed	
New Germany Rural High School	Cafeteria 3 Bay Sink Dishes	150.0	4.7	Passed	
New Germany Rural High School	Cafeteria Hand Wash Sink	240.0	5.1	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Rm 312 Counter Sink	70.0	4.6	Passed	
New Germany Rural High School	Rm 311 Counter Sink Right	150.0	5.0	Passed	
New Germany Rural High School	Rm 311 Counter Sink Left	330.0	2.2	Passed	
New Germany Rural High School	Upstairs Girls Washroom Sink Right	200.0	3.4	Passed	
New Germany Rural High School	Upstairs Girls Washroom Sink Middle	250.0	3.8	Passed	
New Germany Rural High School	Upstairs Girls Washroom Sink Middle	180.0	2.8	Passed	
New Germany Rural High School	Upstairs Girls Washroom Sink Left	210.0	3.7	Passed	
New Germany Rural High School	Upstairs Jan Room Next To Girls Was	190.0	5.3	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Upstairs Staff Washroom Sink	120.0	6.8	Exceeds Limit	Signage to be added to instruct handwashing only
New Germany Rural High School	Upstairs Boys Washroom Sink Right	180.0	3.1	Passed	
New Germany Rural High School	Upstairs Boys Washroom Sink Middle	200.0	3.4	Passed	
New Germany Rural High School	Upstairs Boys Washroom Sink Middle	220.0	4.0	Passed	
New Germany Rural High School	Upstairs Boys Washroom Sink Left	210.0	3.8	Passed	
New Germany Rural High School	Upstairs Fountain Across fr 307	330.0	1.1	Passed	
New Germany Rural High School	Upstairs Fountain Across fr 303	460.0	1.3	Passed	
New Germany Rural High School	Rm 303 Staff Washroom	240.0	1.7	Passed	
New Germany Rural High School	Rm 314 Jan Rm Laundry Tub	110.0	9.3	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	First floor boys washroom Right	3,300.0	6.8	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	First floor boys washroom Middle	3,300.0	6.7	Exceeds Limit	Signage to be added to instruct handwashing only

New Ross Consolidated School	First floor boys washroom Middle	3,100.0	7.5	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	First floor boys washroom Left	2,900.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	First floor girls washroom Right	2,700.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	First floor girls washroom Middle	3,000.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	First floor girls washroom Middle	2,900.0	6.9	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	First floor girls washroom Left	3,100.0	7.3	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Pre-primary washroom	2,900.0	7.8	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Custodian sink	3,600.0	18.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Fountain first floor near washrooms	950.0	2.5	Passed	
New Ross Consolidated School	Office wahroom sink	1,100.0	18.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	108 counter sink	40.0	4.8	Passed	
New Ross Consolidated School	108 washroom tap	880.0	62.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	110 set tub taps	700.0	140.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Phys Ed office washroom	3,600.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	109 first sink	1,400.0	57.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	109 far left	820.0	4.0	Passed	
New Ross Consolidated School	Gym fountain	390.0	1.2	Passed	
New Ross Consolidated School	Main cafeteria sink	290.0	4.2	Passed	
New Ross Consolidated School	Eating area clean up sink	2,200.0	37.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Boys locker room sink	2,200.0	140.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Girls locker room sink	5,100.0	42.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Upstairs boys washroom Right	3,600.0	12.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Upstairs boys washroom Middle	3,500.0	9.1	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Upstairs boys washroom Middle	2,700.0	7.4	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Upstairs boys washroom Left	1,600.0	9.1	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Upstairs custodian room	1,600.0	8.9	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Upstairs fountain	320.0	3.3	Passed	
New Ross Consolidated School	Upstairs girls washroom Right	3,100.0	22.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Upstairs girls washroom Middle	3,000.0	22.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Upstairs girls washroom Middle	2,700.0	15.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Upstairs girls washroom Left	2,300.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	203 counter sink	3,200.0	56.0	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Staff room (upstairs)	9.4	1.7	Passed	
New Ross Consolidated School	109 Middle	200.0	4.0	Passed	

New Ross Consolidated School	Pre-primary counter sink	24.0	2.6	Passed	
New Ross Consolidated School	109 Middle	24.0	4.6	Passed	
New Ross Consolidated School	Staff room (upstairs)	200.0	7.3	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	109 Middle	58.0	5.1	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	Staff room (upstairs)	140.0	6.7	Exceeds Limit	Signage to be added to instruct handwashing only
New Ross Consolidated School	109 Middle	3.3	2.0	Passed	
New Ross Consolidated School	Staff room (upstairs)	410.0	5.5	Exceeds Limit	Signage to be added to instruct handwashing only
Newcombville Elementary School	Near 6 fountain	71.0	5.6	Exceeds Limit	Removed, out of service
Newcombville Elementary School	Near 12 fountain	49.0	6.2	Exceeds Limit	Removed, out of service
Newcombville Elementary School	4 counter sink	190.0	2.8	Passed	
Newcombville Elementary School	cafeteria counter sink	590.0	4.8	Passed	
Newcombville Elementary School	cafeteria hand wash sink	690.0	4.3	Passed	
Newcombville Elementary School	Small janitor's room sink	980.0	9.7	Exceeds Limit	Signage to be added to instruct handwashing only
Newcombville Elementary School	Custodial supply room (Dave's office)	1,000.0	10.0	Exceeds Limit	Signage to be added to instruct handwashing only
Newcombville Elementary School	Girls washroom sink Right	480.0	3.8	Passed	
Newcombville Elementary School	Girls washroom sink Middle	450.0	2.9	Passed	
Newcombville Elementary School	Girls washroom sink Middle	570.0	3.1	Passed	
Newcombville Elementary School	Girls washroom sink Left	610.0	37.0	Exceeds Limit	Signage to be added to instruct handwashing only
Newcombville Elementary School	Special needs washroom sink	43.0	9.1	Exceeds Limit	Signage to be added to instruct handwashing only
Newcombville Elementary School	Across from room 2 hallway fountain	280.0	0.5	Passed	
Newcombville Elementary School	Student washroom sink	510.0	4.7	Passed	
Newcombville Elementary School	washroom sink	1,000.0	6.3	Exceeds Limit	Signage to be added to instruct handwashing only
Newcombville Elementary School	Staff washroom sink	550.0	8.2	Exceeds Limit	Signage to be added to instruct handwashing only
Newcombville Elementary School	Fountain near boys washroom	46.0	2.8	Passed	
Newcombville Elementary School	Boys washroom sink Right	460.0	7.3	Exceeds Limit	Signage to be added to instruct handwashing only
Newcombville Elementary School	Boys washroom sink Middle	480.0	3.9	Passed	
Newcombville Elementary School	Boys washroom sink Middle	510.0	4.6	Passed	
Newcombville Elementary School	Boys washroom sink Left	460.0	4.5	Passed	
Newcombville Elementary School	Pre-primary washroom sink	680.0	1.7	Passed	
Newcombville Elementary School	Pre-primary counter sink	640.0	1.6	Passed	
Newcombville Elementary School	Across from room 2 hallway fountain	27.0	0.1	Passed	
North Queens Community School	Washroom in Office	840.0	6.6	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 1021 Counter Sink Pre Primary	340.0	0.9	Passed	
North Queens Community School	Fountain in Main Lobby	310.0	-	Passed	

North Queens Community School	Fountain in Hall by Gym	180.0	-	Passed	
North Queens Community School	fountain Upstairs Hall near 2017	200.0	1.1	Passed	
North Queens Community School	Fountain Upstairs Hall Near 2109	220.0	0.8	Passed	
North Queens Community School	Rm 1028 Counter Sink	1,300.0	110.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 1030 Counter Sink	440.0	16.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 1024 Counter Sink	650.0	45.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 1022 Counter Sink	93.0	1.5	Passed	
North Queens Community School	Boys Washroom in Lobby Right	2,100.0	19.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Boys Washroom in Lobby Left	350.0	25.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Fountain in Main Lobby	540.0	18.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Girls Washroom in Lobby Right	460.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Girls Washroom in Lobby Left	480.0	2.0	Passed	
North Queens Community School	Lobby Staff/Pre Primary Washroom S	440.0	0.7	Passed	
North Queens Community School	Lobby Janitors Closet Mop Sink	510.0	4.1	Passed	
North Queens Community School	rm 1107 Tech Laundry tub	160.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Boiler Rm Mop Sink	330.0	7.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	rm 1111 Janitors Closet	870.0	100.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Learning Commons Counter Sink	230.0	1.7	Passed	
North Queens Community School	Girls Washroom by Gym Right	130.0	4.0	Passed	
North Queens Community School	Girls Washroom by Gym Middle	97.0	2.7	Passed	
North Queens Community School	Girls Washroom by Gym Left	120.0	3.3	Passed	
North Queens Community School	Boys Washroom by Gym Right	110.0	2.7	Passed	
North Queens Community School	Boys Washroom by Gym left	74.0	5.4	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Girls Locker Room Sink	480.0	32.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 1146 Gym Office Washroom Sink	230.0	19.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 1148 Gym Office Washroom Sink	160.0	21.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 1115 Chem Lab	620.0	50.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Start on Right Circle to Left	890.0	130.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		810.0	150.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		2,500.0	900.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		420.0	46.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		700.0	90.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		660.0	69.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		740.0	87.0	Exceeds Limit	Signage to be added to instruct handwashing only

North Queens Community School		1,500.0	230.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		1,300.0	380.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		1,300.0	460.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		1,000.0	290.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		1,600.0	160.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		3,300.0	740.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School		5,300.0	390.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 1115	740.0	250.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 1115 Front of Class	1,800.0	160.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 1117 Back Rm/Chem Storage Co	650.0	130.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2025 Music Counter Sink	1,600.0	8.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2019 Art Counter Sink Right	270.0	6.3	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2019 Art Counter Sink Left	280.0	8.7	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2014 Staff Washroom Right	710.0	12.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2014 Staff Washroom Left	740.0	13.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2017 Art Counter Sink Right	230.0	2.4	Passed	
North Queens Community School	Rm 2017 Art Counter Sink Middle	59.0	3.8	Passed	
North Queens Community School	Rm 2017 Art Counter Sink Left	310.0	6.8	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Upstairs boys Washroom right	670.0	27.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Upstairs Boys Washroom Left	460.0	39.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Upstairs Girls Washroom Right	380.0	27.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Upstairs Girls Washroom Left	350.0	18.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2009 Counter Sink Right	280.0	7.9	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2009 Counter Sink Teachers Desk	90.0	4.5	Passed	
North Queens Community School	Rm 2009 Counter Sink Left	320.0	5.1	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2002 Janitor closet mop sink	550.0	45.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	upstairs Boys (Old Part) sink Right	160.0	3.0	Passed	
North Queens Community School	Upstairs Boys (Old Part) sink Left	140.0	1.5	Passed	
North Queens Community School	Rm 2109 Janitor sink	450.0	19.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Upstairs Girls (Old Part) Right	92.0	2.4	Passed	
North Queens Community School	Upstairs Girls (Old Part) Left	97.0	1.7	Passed	
North Queens Community School	Rm 2110 Special Needs Washroom	170.0	14.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2123 Teen Health Bathroom Sink	100.0	4.6	Passed	
North Queens Community School	Cafeteria Counter Sink Right	23.0	2.3	Passed	

North Queens Community School	Cafeteria counter sink left	45.0	3.0	Passed	
North Queens Community School	Rm 1120 Kit on Right	25.0	5.0	Passed	
North Queens Community School	Rm 1120 kit in Middle	5.7	2.0	Passed	
North Queens Community School	Rm 1120 Kit on Left Middle	23.0	5.0	Passed	
North Queens Community School	Rm 1120 Kit on Left Middle	71.0	5.0	Passed	
North Queens Community School	Rm 1120A Counter Sink in Back Rm	87.0	5.0	Exceeds Limit	Signage to be added to instruct handwashing only
North Queens Community School	Rm 2110 Kitchenette Counter Sink	32.0	1.0	Passed	
North Queens Community School	Fountain Upstairs Hall Near 2109	330.0	3.1	Passed	
North Queens Community School	Cafeteria Counter Sink Right	65.0	3.3	Passed	
North Queens Community School	Cafeteria Counter Sink Left	84.0	3.9	Passed	
North Queens Community School	Rm 2014 Staff Counter Sink	13.0	5.0	Passed	
North Queens Community School	Rm 2110 Kitchenette Counter Sink	68.0	3.3	Passed	
North Queens Community School	Rm 1120 Kit on Right	26.0	3.6	Passed	
North Queens Community School	Rm 1120 kit in Middle	54.0	2.4	Passed	
North Queens Community School	Rm 1120 Kit on Left Middle	46.0	4.1	Passed	
Park View Education Centre	Next to rm 233 Fountain	53.0	-	Passed	
Park View Education Centre	Rm 127 Cafeteria Center Island	150.0		Passed	
Park View Education Centre	Across from Rm 124 Fountain	39.0	-	Passed	
Park View Education Centre	Rm 120 Counter Sink	160.0	-	Passed	
Park View Education Centre	Near Gym Fountain	150.0		Passed	
Park View Education Centre	231 Counter Sink Resource	92.0		Passed	
Park View Education Centre	Rm 222 Nutrition Rm Counter Sink Ri	140.0	1.0	Passed	
Park View Education Centre	Rm 222 Counter Sink Middle	70.0	-	Passed	
Park View Education Centre	Rm 222 Counter Sink Middle	67.0	-	Passed	
Park View Education Centre	Rm 222 Counter Sink on Left	100.0	-	Passed	
Park View Education Centre	Rm 220 PLC Counter Sink	83.0	-	Passed	
Park View Education Centre	Rm 207 Counter Sink Resource	240.0		Passed	
Park View Education Centre	Rm 126 Kitchen Area Tap	200.0	0.1	Passed	
Park View Education Centre	Rm 133 Counter Sink	74.0	1.6	Passed	
Park View Education Centre	Rm 135 Counter Sink	77.0	-	Passed	
Park View Education Centre	Near 135 Staff Rm Bathroom Sink	530.0	4.4	Passed	
Park View Education Centre	Rm 139 Music Rm Laundry Sink	150.0	0.9	Passed	
Park View Education Centre	Rm 129 Counter Sink Right	260.0	1.1	Passed	
Park View Education Centre	Rm 129 Counter Sink Left	270.0	1.1	Passed	

Park View Education Centre	Rm 130 Tech Laundry Tub	220.0	1.6	Passed	
Park View Education Centre	Rm 127 Dish Sink Right	330.0	1.8	Passed	
Park View Education Centre	Rm 127 Dish Sink Left	54.0	-	Passed	
Park View Education Centre	Rm 127 Hand Sink Left	130.0	-	Passed	
Park View Education Centre	Rm 126 Bathroom Tap	110.0	-	Passed	
Park View Education Centre	Downstairs Individual Washrooms	49.0	-	Passed	
Park View Education Centre	Start on Right From Hallway	44.0	-	Passed	
Park View Education Centre		51.0	-	Passed	
Park View Education Centre		190.0	0.9	Passed	
Park View Education Centre		69.0	-	Passed	
Park View Education Centre		35.0	-	Passed	
Park View Education Centre		120.0	0.6	Passed	
Park View Education Centre		1,300.0	5.7	Exceeds Limit	Signage to be added to instruct handwashing only
Park View Education Centre		64.0	-	Passed	
Park View Education Centre		110.0	0.6	Passed	
Park View Education Centre	Last Door on Left (Back to Hall)	60.0	-	Passed	
Park View Education Centre	Rm 105 Janitors Sink	41.0	0.6	Passed	
Park View Education Centre	Rm 104 Counter Sink	110.0	-	Passed	
Park View Education Centre	In Office Nurses Station Bathroom	440.0	3.3	Passed	
Park View Education Centre	In Office Staff Washroom	320.0	1.9	Passed	
Park View Education Centre	Hallway Near Gym Bathroom Right	120.0	-	Passed	
Park View Education Centre	Hallway Near Gym Bathroom Middle	140.0	0.5	Passed	
Park View Education Centre	Hallway Near Gym Bathroom Left	92.0	-	Passed	
Park View Education Centre	Hallway Near Gym Janitors Rm	36.0	1.1	Passed	
Park View Education Centre	In Gym Girls Locker Rm Right	96.0	-	Passed	
Park View Education Centre	In Gym Girls Locker Rm Left	120.0	-	Passed	
Park View Education Centre	In Gym Girls Shower Rm Sink	140.0	9.4	Exceeds Limit	Signage to be added to instruct handwashing only
Park View Education Centre	In Gym Teachers Office Bathroom	100.0	-	Passed	
Park View Education Centre	In Gym Boys Locker Rm Right	150.0	1.3	Passed	
Park View Education Centre	In Gym Boys Locker Rm Left	130.0	0.9	Passed	
Park View Education Centre	233 Upstairs Staff Washroom Sink	170.0	1.0	Passed	
Park View Education Centre	236W Counter Sink Right	78.0	-	Passed	
Park View Education Centre	236 Counter Sink Middle	63.0	-	Passed	
Park View Education Centre	236 Counter Sink Middle	62.0	-	Passed	

Park View Education Centre	236 Counter Sink Left	77.0	-	Passed
Park View Education Centre	234W Counter Sink Right	60.0	-	Passed
Park View Education Centre	234W Counter Sink Middle	69.0	-	Passed
Park View Education Centre	234W Counter Sink Middle	42.0	-	Passed
Park View Education Centre	234W Counter Sink Middle	46.0	-	Passed
Park View Education Centre	234W Counter Sink Middle	34.0	-	Passed
Park View Education Centre	234W Counter Sink Middle	46.0	-	Passed
Park View Education Centre	234W Counter Sink Middle	65.0	-	Passed
Park View Education Centre	234W Counter Sink Left	44.0	-	Passed
Park View Education Centre	Rm227 Bio. Counter Sink Right	31.0	-	Passed
Park View Education Centre	Rm 227 Bio. Counter Sink Middle	51.0	0.9	Passed
Park View Education Centre	Rm 227 Bio. Counter Sink Middle	37.0	2.1	Passed
Park View Education Centre	Rm 227 Bio. Counter Sink Middle	25.0	-	Passed
Park View Education Centre	Rm 227 Bio. Counter Sink Middle	23.0	-	Passed
Park View Education Centre	Rm 227 Bio. Counter Sink Left	17.0	0.8	Passed
Park View Education Centre	Rm 226 Visual Arts Counter Left	28.0	-	Passed
Park View Education Centre	Rm 226 Visual Arts Counter Right	50.0	-	Passed
Park View Education Centre	Rm 224 Visual Arts Counter Left	70.0	-	Passed
Park View Education Centre	Rm 224 Visual Arts Counter Right	65.0	-	Passed
Park View Education Centre	Upstairs Washrooms First Right	74.0	-	Passed
Park View Education Centre	Entering From Hall	86.0	0.8	Passed
Park View Education Centre	Hallway	530.0	2.7	Passed
Park View Education Centre	Hallway	50.0	-	Passed
Park View Education Centre	Hallway	52.0	-	Passed
Park View Education Centre	Hallway	30.0	-	Passed
Park View Education Centre	Hallway	38.0	-	Passed
Park View Education Centre	Hallway	40.0	-	Passed
Park View Education Centre	Last on Left	33.0	-	Passed
Park View Education Centre	Rm 203 Jan. Closet Sink	48.0	-	Passed
Park View Education Centre	Rm 202 Counter Sinks Right	100.0	1.1	Passed
Park View Education Centre	Rm 202 Counter Sink Left	90.0	1.2	Passed
Park View Education Centre	Blue Portable Near Skilled Trade Batf	320.0	1.2	Passed
Park View Education Centre	225 bio lab first on right	22.0	-	Passed
Park View Education Centre	225 bio lab middle	14.0	-	Passed

Park View Education Centre	225 bio lab middle	48.0	-	Passed	
Park View Education Centre	225 bio lab middle	40.0	-	Passed	
Park View Education Centre	225 bio lab middle	65.0	-	Passed	
Park View Education Centre	225 bio lab last left (hand wash)	49.0	-	Passed	
Park View Education Centre	Rm 228 physics lab first right	43.0	-	Passed	
Park View Education Centre	Rm 228 physics lab middle	48.0	-	Passed	
Park View Education Centre	Rm 228 physics lab middle	25.0	0.6	Passed	
Park View Education Centre	Rm 228 physics lab last left	19.0	-	Passed	
Pentz Elementary School	Near Janitor's Room fountain	120.0	4.2	Passed	
Pentz Elementary School	Small staff washroom in girls washro	340.0	3.0	Passed	
Pentz Elementary School	Girls washroom Right	230.0	8.6	Exceeds Limit	Signage to be added to instruct handwashing only
Pentz Elementary School	Girls washroom middle	180.0	6.0	Exceeds Limit	Signage to be added to instruct handwashing only
Pentz Elementary School	Girls washroom middle	200.0	15.0	Exceeds Limit	Signage to be added to instruct handwashing only
Pentz Elementary School	Girls washroom Left	170.0	9.2	Exceeds Limit	Signage to be added to instruct handwashing only
Pentz Elementary School	Janitor's closet	310.0	4.8	Passed	
Pentz Elementary School	Staff Room counter sink	370.0	1.3	Passed	
Pentz Elementary School	Pre Primary counter sink	310.0	0.9	Passed	
Pentz Elementary School	Pre Primary Washroom	81.0	5.6	Exceeds Limit	Signage to be added to instruct handwashing only
Pentz Elementary School	Principal's Washroom	280.0	16.0	Exceeds Limit	Signage to be added to instruct handwashing only
Pentz Elementary School	Fountain on office side of building	99.0	1.0	Passed	
Pentz Elementary School	Boys Washroom Right	130.0	7.5	Exceeds Limit	Signage to be added to instruct handwashing only
Pentz Elementary School	Boys Washroom Middle	89.0	4.6	Passed	
Pentz Elementary School	Boys Washroom Middle	77.0	5.6	Exceeds Limit	Signage to be added to instruct handwashing only
Pentz Elementary School	Boys Washroom Left	170.0	19.0	Exceeds Limit	Signage to be added to instruct handwashing only
Pentz Elementary School	Small washroom in boys washroom	270.0	3.2	Passed	
Pentz Elementary School	Kitchen Right	15.0	3.2	Passed	
Pentz Elementary School	Kitchen Left	19.0	2.2	Passed	
Petite Rivière Elementary School	Fountain in Gym Near Front Door	37.0	1.7	Passed	
Petite Rivière Elementary School	Rm Pre Primary Classroom Sink	74.0	7.0	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Staff Washroom in Office	90.0	10.0	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Counter Sink on the Stage (NOT IN U'	3,000.0	1,400.0	Exceeds Limit	Remediation has been completed
Petite Rivière Elementary School	Staff Room Bathroom Sink	130.0	34.0	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Boys Washroom Laundry Tub	67.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Boys Washroom Sink Right	130.0	60.0	Exceeds Limit	Signage to be added to instruct handwashing only

Petite Rivière Elementary School	Boys Washroom Sink Middle	62.0	27.0	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Boys Washroom Sink Left	63.0	28.0	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Janitors Closet in Gym	44.0	4.3	Passed	
Petite Rivière Elementary School	Girls Washroom Laundry Tub	110.0	8.9	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Girls Washroom Sink Right	120.0	24.0	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Girls Washroom Sink Middle	130.0	32.0	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Girls Washroom Sink Left	110.0	14.0	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Rm Pre Primary Washroom Sink	230.0	37.0	Exceeds Limit	Signage to be added to instruct handwashing only
Petite Rivière Elementary School	Staff Rm Counter Sink	2.2	-	Passed	
Petite Rivière Elementary School	Rm Pre Primary Classroom Sink	17.0	1.8	Passed	
Petite Rivière Elementary School	Staff Rm Counter Sink	13.0	2.8	Passed	
Petite Rivière Elementary School	Rm Pre Primary Classroom Sink	11.0	2.0	Passed	
Petite Rivière Elementary School	Rm Pre Primary Classroom Sink		5.2	Exceeds Limit	Signage to be added to instruct handwashing only
South Queens Middle School	Rm 123A Laundry Sink	83.0	1.6	Passed	
South Queens Middle School	Rm 125 Family Studies Counter Sink I	76.0	0.7	Passed	
South Queens Middle School	Rm 125 Family Studies Counter Sink I	130.0	1.4	Passed	
South Queens Middle School	Rm 125 Family Studies Counter Sink I	63.0		Passed	
South Queens Middle School	Rm 125 Family Studies Counter Sink I	59.0	0.5	Passed	
South Queens Middle School	Rm 125 Family Studies Counter Sink I	210.0	1.8	Passed	
South Queens Middle School	Rm 121 Multi Purpose Counter Sink F	110.0	2.8	Passed	
South Queens Middle School	Rm 121 Multi Purpose Counter Sink F	90.0	1.1	Passed	
South Queens Middle School	Rm 121 Multi Purpose Counter Sink F	130.0	1.8	Passed	
South Queens Middle School	Rm 121 Multi Purpose Counter Sink F	100.0	1.0	Passed	
South Queens Middle School	Rm 121 Multi Purpose Counter Sink I	74.0	0.7	Passed	
South Queens Middle School	Near 128 Fountain	230.0		Passed	
South Queens Middle School	127 Bathroom Sink	250.0	1.0	Passed	
South Queens Middle School	128 Counter Sink	62.0		Passed	
South Queens Middle School	129 Art Counter Sink Right	500.0	4.0	Passed	
South Queens Middle School	129 Art Counter Sink Left	78.0		Passed	
South Queens Middle School	136 Shop Laundry Tub	230.0	2.8	Passed	
South Queens Middle School	138 Counter Sink	180.0	1.0	Passed	
South Queens Middle School	139 Bathroom Sink	110.0		Passed	
South Queens Middle School	112 Bathroom Sink Staff	90.0		Passed	
South Queens Middle School	111 Boys Bathroom Sink Right	130.0	0.7	Passed	

South Queens Middle School	111 Boys Bathroom Sink Middle	170.0	0.6	Passed	
South Queens Middle School	111 Boys Bathroom Sink Left	240.0		Passed	
South Queens Middle School	110 Girls Bathroom Sink Right	160.0	0.8	Passed	
South Queens Middle School	110 Girls Bathroom Sink Middle	160.0	0.9	Passed	
South Queens Middle School	110 Girls Bathroom Sink Left	160.0	0.7	Passed	
South Queens Middle School	Rm 143 Janitors Sink	240.0	1.9	Passed	
South Queens Middle School	Rm 106 Washroom Sink	290.0		Passed	
South Queens Middle School	Rm 150 Washroom Sink	110.0	0.6	Passed	
South Queens Middle School	Rm 153 Washroom Sink	160.0	1.1	Passed	
South Queens Middle School	Rm 148 (upstairs sink) Wash Tub	290.0	508.0	Exceeds Limit	Signage to be added to instruct handwashing only
South Queens Middle School	Rm 156 Music Counter Sink	110.0	1.4	Passed	
South Queens Middle School	Cafeteria Fountain	220.0		Passed	
South Queens Middle School	Change Rm (right) Sink on Right	290.0	0.7	Passed	
South Queens Middle School	Change Rm (right) Sink on Left	230.0	0.6	Passed	
South Queens Middle School	Change Rm (left) Sink on Right	200.0	0.6	Passed	
South Queens Middle School	Change Rm (left) Sink on Left	160.0	0.9	Passed	
South Queens Middle School	Rm 172 Jan. Floor Sink	130.0	5.7	Exceeds Limit	Signage to be added to instruct handwashing only
South Queens Middle School	Rm 172 Jan. Counter Sink	160.0	0.8	Passed	
South Queens Middle School	Rm 170 cafeteria Right Rear Corner	93.0	10.0	Exceeds Limit	Signage to be added to instruct handwashing only
South Queens Middle School	Rm 170 Cafeteria 3 bay sink (dishes)	120.0		Passed	
South Queens Middle School	Rm 170 Cafeteria Island Sink	36.0		Passed	
South Queens Middle School	Rm 170 Cafeteria Hand Wash Sink	99.0	0.9	Passed	
Verge House	Kitchen tap	140.0	3.1	Passed	
Verge House	First floor bathroom tap	94.0	1.0	Passed	
Verge House	Second floor bathroom tap	130.0	3.6	Passed	
West Northfield Elementary School	Near 117 (Boiler Room) water founta	870.0	3.5	Passed	
West Northfield Elementary School	Near 117 (Boiler Room) water founta	470.0	3.9	Passed	
West Northfield Elementary School	116 Boys washroom 1st floor Right	710.0	3.6	Passed	
West Northfield Elementary School	116 Boys washroom 1st floor Middle	460.0	2.7	Passed	
West Northfield Elementary School	116 Boys washroom 1st floor Left	700.0	4.0	Passed	
West Northfield Elementary School	110 Girls washroom 1st floor Right	520.0	3.4	Passed	
West Northfield Elementary School	110 Girls washroom 1st floor Middle	490.0	5.7	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	110 Girls washroom 1st floor Left	380.0	2.8	Passed	
West Northfield Elementary School	106 Classroom sink	650.0	45.0	Exceeds Limit	Signage to be added to instruct handwashing only

West Northfield Elementary School	106 Washroom in classroom	550.0	4.9	Passed	
West Northfield Elementary School	107 Classroom sink	860.0	14.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	102 Washroom in classroom	500.0	2.3	Passed	
West Northfield Elementary School	102 Classroom sink	690.0	6.8	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	104 Classroom sink	630.0	10.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	120 Janitor's sink	1,000.0	25.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	124 Staff washroom	690.0	24.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	127 Staff washroom	510.0	3.6	Passed	
West Northfield Elementary School	140 Girls washroom 1st floor by Cafe	710.0	18.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	140 Girls washroom 1st floor by Cafe	940.0	42.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	140 Girls washroom 1st floor by Cafe	880.0	9.1	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	141 Janitor's Room	460.0	11.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	142 Special needs washroom 1st floo	430.0	3.7	Passed	
West Northfield Elementary School	142 Special needs washroom 1st floo	430.0	4.0	Passed	
West Northfield Elementary School	135 Cafeteria right of dishwasher	670.0	16.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	135 Cafeteria left of dishwasher	880.0	15.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	Near 153 fountain in main foyer	410.0	1.2	Passed	
West Northfield Elementary School	154 Girls change room sink	720.0	6.3	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	Gym teacher's office	610.0	22.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	161 Boys change room sink	710.0	7.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	213 Boys washroom 2nd floor Right	560.0	3.2	Passed	
West Northfield Elementary School	213 Boys washroom 2nd floor Middle	530.0	4.3	Passed	
West Northfield Elementary School	213 Boys washroom 2nd floor Left	620.0	4.6	Passed	
West Northfield Elementary School	208 Girls washroom 2nd floor Right	710.0	8.7	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	208 Girls washroom 2nd floor Middle	460.0	3.9	Passed	
West Northfield Elementary School	208 Girls washroom 2nd floor Left	760.0	3.5	Passed	
West Northfield Elementary School	218 Janitor's closet	770.0	27.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	205 Classroom sink	580.0	18.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	135 Cafeteria sink far left	410.0	4.4	Passed	
West Northfield Elementary School	138 Music room counter sink	2,400.0	97.0	Exceeds Limit	Signage to be added to instruct handwashing only
West Northfield Elementary School	125 Staff room sink	350.0	4.4	Passed	
West Northfield Elementary School	Near 214 fountain	200.0	3.4	Passed	
West Northfield Elementary School	135 Cafeteria right hand side of coun	41.0	7.5	Exceeds Limit	Faucet to be decommissioned, remediated, and re
West Northfield Elementary School	Near 153 fountain in main foyer	610.0	1.9	Passed	

Not tested. Other sources available

Not tested. Other sources available

Not tested. Other sources available

Not tested. Other sources available